

**2021 PFAS6 Monthly Results & Quarterly Averages: Active Drinking Water Sources**

Sample Collection Date	Water Treatment Plant	Springvale WTP		Elm Bank WTP	Pine Oaks WTP	MCL (ng/L)	QC complete (Y/N)
	EPTDS Location	Tonka	H&T	Elm Bank	Pine Oaks		
1/27/2021	January	19.71	25.07	11.30	14.81	<b>20</b>	Y
2/24/2021	February	22.94	24.61	9.97	19.97		Y
3/24/2021	March	21.06	22.06	9.07	18.30		Y
	<b>Quarter 1 Averages</b>	<b>21</b>	<b>24</b>	<b>10</b>	<b>18</b>		<b>N/A</b>
4/21/2021	April	17.99	22.18	8.79	17.47	<b>20</b>	Y
5/26/2021	May	16.26		7.57	16.37		Y
6/23/2021	June	15.43		6.79	13.74		Y
	<b>Quarter 2 Averages</b>	<b>18</b>		<b>7.7</b>	<b>16</b>		<b>N/A</b>
7/21/2021	July	21.18		12.34	17.14	<b>20</b>	Y
8/18/2021	August	19.46		12.54	16.74		Y
9/15/2021	September	20.60		10.32	17.10		Y
	<b>Quarter 3 Averages</b>	<b>20</b>		<b>12</b>	<b>17</b>		<b>N/A</b>
10/13/2021	October	21.02		11.45	14.29	<b>20</b>	Y
11/10/2021	November	23.01		12.15	16.94		Y
12/27/2021	December	19.03		11.28	13.72		Y
	<b>Quarter 4 Averages</b>	<b>21</b>		<b>12</b>	<b>15</b>		<b>N/A</b>

**2021 PFAS6 Monthly Results & Quarterly Averages: Inactive Drinking Water Sources**

Sample Collection Date	Water Treatment Plant	Morses Pond WTP	MCL (ng/L)	QC complete (Y/N)
	EPTDS Location	Morses Pond		
1/27/2021	January	32.85	<b>20</b>	Y
2/24/2021	February	76.61		Y
3/24/2021	March	87.08		Y
	<b>Quarter 1 Averages</b>	<b>66</b>		<b>N/A</b>
4/21/2021	April	72.15	<b>20</b>	Y
5/26/2021	May	40.69		Y
6/30/2021	June	41.66		Y
	<b>Quarter 2 Averages</b>	<b>52</b>		<b>N/A</b>
7/21/2021	July	72.45	<b>20</b>	Y
8/18/2021	August	48.68		Y
9/15/2021	September	58.74		Y
	<b>Quarter 3 Averages</b>	<b>60</b>		<b>N/A</b>
10/13/2021	October	51.79	<b>20</b>	Y
11/10/2021	November	65.14		Y
12/27/2021	December	58.77		Y
	<b>Quarter 4 Averages</b>	<b>59</b>		<b>N/A</b>

**KEY:**

EPTDS = Entry Point To Distribution System (the location where treated water enters the drinking water system)

ng/L = nanograms per liter, also equal to parts per trillion (ppt)

MCL = Maximum Contaminant Level (highest amount allowed by regulation)

QC = Quality Control report, this determines if a sample result is valid or invalid for various lab processing reasons

**NOTES:**

Yellow highlight = Violation

Violation/compliance with regulation based on locational Quarterly Averages

Morses Pond is currently an inactive source

Water from all active EPTDSs combine in Natick's drinking water distribution system

In May 2021, Springvale Tonka and H&T were combined to produce a blended EPTDS