




Natick Fire Department

22 EAST CENTRAL STREET, NATICK, MASSACHUSETTS 01760

Jason P. Ferschke
Chief of Department

508-647-9559

jferschke@natickma.org



Kitchen Suppression Systems Closeout Documents

The following is a list of documentation that must be uploaded to the Open Gov permit for the project in order for the fire department to sign off on final occupancy. This list of documentation is for a standard project. If a particular form is not applicable, then this information must be coordinated with the Fire Prevention Division. From time to time additional documentation may be required based on the project.

1. Registered Design Professional affidavit indicating that the complete sprinkler system has been installed per all applicable codes (NFPA 13), rules, laws, regulations, and plans.